Contact-Duo-Profile 3100.0118

Functional description of the system

The evaluation electronics monitor the safety strip, which is equipped with a terminating resistor and operates using the closed circuit principle. An amount of current defined by the resistance (8.2 k Ω) flows through the safety strip. When mechanical pressure causes the resistance in the safety strip to drop below 5.5 k Ω , this is recognised as an actuation (evaluation electronics: LED RED). When contact resistance or a broken cable raises the resistance in the safety strip above 11.5 k Ω , this condition is recognised as a broken cable and/or fault (evaluation electronics: LED YELLOW). In both cases, the system stops (evaluation electronics: safety relays K1 and K2 open).




Contact-Duo 3100.0118

Contact-Duo-Profile	
Article no.	3100.0118
Material	EPDM
Weight	0.259 kg/m
Shore hardness	Conductive mixture: 62+/-5 Shore A
	Non-conductive mixture: 60+/-5 Shore A
Interconnection	Series connection electr. max. 10 switching strips
Min. and max. length of the	0.1 m to 100 m
switching strip	
Storage temperature	-10°C to +15°C respectively +25°C (DIN 7716)
Delivery length	30 m
Response time of the evaluation	< 12 ms
electronics	

Certified characteristic data	
Actuation force	28 N bei 200 mm/s
Actuation angle (α)	+/-45°
Ineffective border area	0 mm, 30 mm with finger safety
Finger safety	yes
Max. operating speed	200 mm/s
Climatic conditions	−10°C to +55°C
Level of protection	IP67
Number of switching cycles	≥ 10,000 Switching cycles

Deformation travels	
Test temperature	20°C
Speed	200 mm/s
Actuation force	28,0 N
Pre-travel at max. operating speed	6.0 mm
Working travel 600N	10.0 mm
Compensation travel at 250 N	4.0 mm*
Compensation travel at 400 N	6.0 mm*
* Reduction because of recovery	



For dimensions without tolerance particulars, tolerance-free dimensions as per DIN ISO 3302-1 E2 shall apply.

You can choose any of several different variants for compatible evaluation signals (Category 1/PL c and Category 3/PL e, SIL3).

